

**Aei**<sup>®</sup>

artificial  
energy  
intelligence

enerGQ<sup>™</sup>

# Industrial Heat & Power / Project 6-25

**(Aei<sup>®</sup>) - CO<sub>2</sub> impact with AI**

**12-10-2021 Rob Burghard**


[www.energq.com](http://www.energq.com)

# Translation of the Law of conservation of energy into technology



ASSET DATA &  
**EXISTING** KNOWLEDGE

Asset performance



+



**ENERGY** &  
WEATHER DATA

Additional sensors




+



ARTIFICIAL ENERGY  
INTELLIGENCE (Aei)

technology



=



ENERGY SAVINGS  
INCREASE MTTF  
**NEW** KNOWLEDGE


added values



# Effect of descaling closed circuit open cooling towers


## Power consumption in kWh

Timespan: From: 01-10-2020 00:00:00 Until: 22-01-2021 12:00:00 Time: - Value: - export ?  Instant graph  Cumulative graph



Learning period: October 1 – January 22

# Effect of descaling closed circuit open cooling towers CUSUM in kWh




**Learning period: October 1 – January 22**



# Effect of descaling closed circuit open cooling towers

## Power consumption in kWh


Timespan: From: 01-10-2020 00:00:00 Until: 22-01-2021 12:00:00 Time: - Value: -  
 Instant graph  Cumulative graph  
 export ?



**Learning period: October 1 – December 16**

# Effect of descaling closed circuit open cooling towers CUSUM in kWh


Timespan: From: 01-10-2020 00:00:00 Until: 22-01-2021 12:00:00  
Time: - Value: -  
export ?  
 Instant graph  
 Cumulative graph




Learning period: October 1 – December 16



Cusum of electricity savings in a building with a production facility




# Condition monitoring relay failure 'Early Warning'







## Potential scan for maximising value from energy



# Maximising value from energy



# Solution architecture for customers with and without PI systems



\* on-premise installation with access by enerGQ is optional.

# Thank you!



Rob Burghard, CEO enerGQ


[rburghard@energq.com](mailto:rburghard@energq.com)

+31 (0)6 10 91 36 93



## More added values of the Artificial Energy Intelligence Software that help to reduce the CO2 footprint

**It detects  
anomalies early**



**It predicts the  
energy consumption**

**It quantifies the  
energy saved**

**It determines the  
energy saving potential**

**It adapts to a  
better performance**




**It advises the  
best energy  
saving setpoints**

**It analyses  
different scenarios**

# Law of energy conservation implies that every combination of parameters relates to an asset's specific *NORMAL* energy consumption

**Weather** (wind speed, wind direction, sun radiation, ambient temperature, wet bulb temperature, rainfall)

**Quantity & Quality** of the energy (power quality, gas quality etc.)




**Performance** (a quantified specific task, often a combination of water level, speed, pressure, weight, flows, temperatures etc.)




**Settings** (all degrees of freedom related to the operation of the asset (setpoints, controls settings, operational status of the asset))

$$E, Q = f(P, W, S, \text{asset condition})$$

# Baselining & calculation of potential operational energy savings



# Monitoring asset status, and energy savings with Aei




# Cooling power consumption in kW without learned reference







# Cooling Plain power consumption in kW with learned reference



# CUSUM in kWh (of power consumption *minus* learned reference)




# Cooling power consumption in kW without learned reference




1. What is Aei?
2. How does it impact CO2 footprints?
3. How can it be applied?
4. **More examples (if time permits)**




## Oasen searching for energy saving opportunity's and monitoring of assets




# Oasen searching for energy saving opportunity's and monitoring of assets



## Oasen Searching for energy saving opportunit's and monitoring of assets



# Power Quality Measurements




RMS	MinPeak	MaxPeak	Angle
220.5 V	-315.2 V	315.2 V	0.0°
221.1 V	-317.0 V	317.9 V	-120.0°
221.5 V	-317.3 V	318.2 V	120.1°
6.64 A	-15.23 A	15.15 A	-7.3°
8.77 A	-16.28 A	15.95 A	-126.1°
8.92 A	-15.83 A	16.13 A	111.5°


Recorded 26/08/20 10:23:50.160  
 Started 26/08/20 10:23:50.000  
 Triggered 26/08/20 10:23:50.000  
 Recording time: 0.160 s  
 Sampling rate: 64 samples/cycle  
 Frequency: 50.01 Hz

SYMMETRICAL COMPONENTS  
 V Positive sequence: 221.0 V  
 V Negative sequence: 0.3 V  
 V Zero sequence: 0.3 V  
 V Negative sequence unbalance: 0.1%  
 V Zero sequence unbalance: 0.1%  
 I Positive sequence: 7.68 A  
 I Negative sequence: 0.18 A  
 I Zero sequence: 0.02 A  
 I Negative sequence unbalance: 2.3%  
 I Zero sequence unbalance: 0.2%

## Cooling fan at pumping station Ijmuiden



Power Quality Measurements



Harmonics					
	HD%	A	HD%	A	
H02	0	0	H03	4.77	0.36
H04	0	0	H05	48.26	3.62
H06	0	0	H07	21.43	1.61
H08	0	0	H09	0.35	0.03
H10	0	0	H11	9.64	0.74
H12	0	0	H13	5.58	0.42
H14	0	0	H15	0.52	0.04
H16	0.43	0.03	H17	5.80	0.43
H18	0	0	H19	4.35	0.33
H20	0	0	H21	0.59	0.04
H22	0	0	H23	7.73	0.58
H24	0.23	0.02	H25	8.74	0.65
H26	0	0	H27	2.83	0.21
H28	0	0	H29	6.56	0.49
H30	0	0	H31	4.15	0.31
H32	0	0	H33	0	0
H34	0	0	H35	0	0
H36	0	0	H37	0	0
H38	0	0	H39	0	0
H40	0	0	H41	0	0
H42	0	0	H43	0	0
H44	0	0	H45	0	0
H46	0	0	H47	0	0
H48	0	0	H49	0	0
H50	0	0	H51	0	0
H52	0	0	H53	0	0
H54	0	0	H55	0	0
H56	0	0	H57	0	0
H58	0	0	H59	0	0
H60	0	0	H61	0	0
H62	0	0	H63	0	0

Current I1  
 RMS: 8.61 A  
 H01 RMS: 7.49 A  
 TOTAL HARMONICS  
 THD: 56.6%  
 Odd harmonics: 56.6%  
 Even harmonics: 0.6%  
 Interharmonics: 0.5%  
 K-Factor: 19.9  
 Crest factor: 1.77  
 Form factor: 1.25  
 Frequency: 50.01 Hz

Cooling fan at  
 pumping station  
 IJmuiden

Over limit



# Power Quality Measurements

BFM oude gemaal pompen Harmonic Spectrum 26/08/20 10:23:50.000															
	Phase L1 V1 THD: 1.5% I1 THD: 56.6%					Phase L2 V2 THD: 1.8% I2 THD: 51.5%					Phase L3 V3 THD: 1.6% I3 THD: 56.7%				
	V1%	I1%	P1%	Q1%	Angle	V2%	I2%	P2%	Q2%	Angle	V3%	I3%	P3%	Q3%	Angle
H01	100.0	100.0	100.0	100.0	7.42°	100.0	100.0	100.0	100.0	6.09°	100.0	100.0	100.0	100.0	8.49°
H02	0	0	0	0	0°	0	0	0	0	0°	0	0	0	0	0°
H03	0	4.8	0	0	132.82°	0.3	6.2	0	-0.2	-59.26°	0	1.7	0	0	116.19°
H04	0	0	0	0	0°	0	0	0	0	0°	0	0.3	0	0	0°
H05	0.8	48.3	0	-3.2	-90.83°	0.8	43.1	0	-3.1	-94.02°	0.8	48.5	-0.2	-2.5	-112.99°
H06	0	0	0	0	0°	0	0	0	0	0°	0	0	0	0	0°
H07	0.6	21.4	-0.1	-0.8	-126.37°	0.7	20.9	0	-1.2	-114.35°	0.7	22.2	0	-1.0	-105.67°
H08	0	0	0	0	0°	0	0	0	0	0°	0	0	0	0	0°
H09	0	0.3	0	0	0°	0.2	1.2	0	0	-91.26°	0	1.1	0	0	0°
H10	0	0	0	0	0°	0	0	0	0	0°	0	0	0	0	0°
H11	0.4	9.8	0	-0.2	-132.35°	0.3	8.2	0	-0.3	-96.63°	0	9.3	0	-0.1	-135.24°
H12	0	0	0	0	0°	0	0	0	0	0°	0	0	0	0	0°
H13	0.3	5.6	0	-0.1	-145.55°	0.3	5.2	0	-0.1	-118.29°	0.3	5.7	0	0	-147.44°
H14	0	0	0	0	0°	0	0	0	0	0°	0	0	0	0	0°
H15	0	0.5	0	0	0°	0.2	1.0	0	0	-151.72°	0	0.7	0	0	0°
H16	0	0.4	0	0	0°	0	0.5	0	0	0°	0	0.5	0	0	0°
H17	0	5.8	0	0	-164.79°	0.4	5.1	0	-0.2	-122.21°	0	5.8	0	0	0°
H18	0	0	0	0	0°	0	0	0	0	0°	0	0	0	0	0°
H19	0	4.4	0	-0.1	-84.29°	0.3	4.2	0	-0.1	-101.51°	0.3	4.5	0	-0.1	-99.22°
H20	0	0	0	0	0°	0	0	0	0	0°	0	0	0	0	0°
H21	0	0.6	0	0	0°	0.3	1.4	0	0	152.93°	0	1.1	0	0	0°
H22	0	0	0	0	0°	0	0	0	0	0°	0	0	0	0	0°
H23	0.4	7.7	0	-0.2	-130.42°	0.7	7.1	0	-0.3	-143.62°	0.7	7.7	0	-0.3	-110.76°
H24	0	0.2	0	0	0°	0	0	0	0	0°	0	0	0	0	0°
H25	0.6	8.7	0	-0.3	-123.79°	0.7	9.3	0	-0.6	-121.91°	0.7	7.4	0	-0.3	-119.87°
H26	0	0	0	0	0°	0	0	0	0	0°	0	0	0	0	0°
H27	0	2.8	0	0	0°	0.4	1.6	0	0	-39.55°	0	1.2	0	0	0°
H28	0	0	0	0	0°	0	0.2	0	0	0°	0	0.3	0	0	0°
H29	0.4	6.6	0	-0.1	-140.55°	0.5	4.4	0	-0.2	-104.71°	0.4	8.0	0	-0.2	-104.07°
H30	0	0	0	0	0°	0	0	0	0	0°	0	0	0	0	0°
H31	0.2	4.1	0	-0.1	-100.56°	0.2	3.1	0	-0.1	-84.35°	0.3	3.7	0	0	-105.64°
H32	0	0	0	0	0°	0	0	0	0	0°	0	0	0	0	0°
H33	0	0	0	0	0°	0	0	0	0	0°	0	0	0	0	0°
H34	0	0	0	0	0°	0	0	0	0	0°	0	0	0	0	0°
H35	0	0	0	0	0°	0	0	0	0	0°	0	0	0	0	0°
H36	0	0	0	0	0°	0	0	0	0	0°	0	0	0	0	0°
H37	0	0	0	0	0°	0	0	0	0	0°	0	0	0	0	0°
H38	0	0	0	0	0°	0	0	0	0	0°	0	0	0	0	0°
H39	0	0	0	0	0°	0	0	0	0	0°	0	0	0	0	0°
H40	0	0	0	0	0°	0	0	0	0	0°	0	0	0	0	0°
H41	0	0	0	0	0°	0	0	0	0	0°	0	0	0	0	0°
H42	0	0	0	0	0°	0	0	0	0	0°	0	0	0	0	0°
H43	0	0	0	0	0°	0	0	0	0	0°	0	0	0	0	0°

Voltage V1  
RMS value: 220.3 V  
THD: 1.5%  
Interharmonics: 0.1%

Current I1  
RMS value: 8.61 A  
THD: 56.6%  
Interharmonics: 0.5%

Voltage V2  
RMS value: 221.3 V  
THD: 1.8%  
Interharmonics: 0.1%

Current I2  
RMS value: 8.75 A  
THD: 51.5%  
Interharmonics: 0.5%

Voltage V3  
RMS value: 221.6 V  
THD: 1.6%  
Interharmonics: 0.1%

Current I3  
RMS value: 8.91 A  
THD: 56.7%  
Interharmonics: 0.4%

Kast RKV 1 pomp 1 ventilator 2 Hoogtoeren

## Introduction to the concept of the Cumulative Sum of the deviation (CUSUM), a simple example

- **Principle:** is simple, sum up the deviation compared to a norm (an estimated average) over time.
- **Challenge:** How to determine the norm?
- **Answer:** By looking at power consumption at specific combinations of contributing factors, which influence the consumption, potentially with a delay.

